

Office of Building Department

Town of Southington, Connecticut

John Smigel
Building Official
(860) 276-6242
Fax (860) 276-6295



John Weichsel
Municipal Center
196 North Main Street
Southington, CT 06489

GENERATOR PERMIT INFORMATION

ADDITIONAL information to be submitted WITH permit application

To obtain a permit for the installation of a generator, the applicant shall FIRST file a permit application along with the following information:

1. A plot plan of the property with the generator location and Zoning approval
2. Type, make and model of the transfer switch to be installed along with cuts / specification sheet
3. Type, make and model of the generator to be installed along with cuts / specifications and clearance requirements for the generator
4. If an automatic transfer switch is proposed to be installed, a load calculation is required in order to show compliance with the capacity and rating requirements of Section 702.4.B. 2 of the 2014 NEC
5. A wiring diagram to show, in detail, the location of the new equipment and the existing equipment, the transfer switch location (before or after the Main breaker), wiring sizes and method. If a whole house transfer switch is being proposed to be installed ahead of the current main disconnect, details on the grounding and bonding arrangement are to be provided.
6. If a permanent generator is being installed, a letter of proper operation is required for the final inspection

The Southington Building Department is offering this handout as a representative of the typical information and / or questions that arise for a typical generator installation job. The Town assumes no responsibility for any errors, omissions that may be found or missing from this handout. This is to be used as a supplement to the normally required information that is submitted on a permit application. The installer is required to follow ALL applicable codes and standards applicable to the installation. This handout cannot possibly cover all situations, set-ups, or configurations, nor is it intended too.
